




Scott P. Morris  
Fire Marshal  
Charlotte County Fire & EMS  
[Scott.morris@charlottecountyfl.gov](mailto:Scott.morris@charlottecountyfl.gov)  
Office: 941.833.5600

**RE: Approved Fire Lanes**

Per the Florida Fire Prevention Code: NFPA 1-18.2.3.6.3 Fire lanes shall be marked with signs that are readily visible to the street with the wording **“NO PARKING FIRE LANE BY ORDER OF THE FIRE DEPARTMENT”**. The following items shall also be required for Fire Lanes.

- (A) All signs shall be 12” in width and 18’ in height
- (B) White background with red letters
- (C) Signs shall be a maximum of 7’ in height from the roadway to the bottom of the sign
- (D) Signs shall be located not more than 60’ apart & within sight of the traffic flow
- (E) Curb of fire lane shall be painted traffic yellow
- (F) In front of the curb shall be painted with diagonal stripes at a 45-degree angle
- (G) The diagonal stripes shall be located not more than 2’ apart
- (H) Fire lane box shall be not more than 4’ in width
- (I) Within the stripes the wording “NO PARKING FIRE LANE” shall be painted within the striping in traffic yellow and shall be 12” x 12” lettering.



Sincerely,

Scott P. Morris  
Fire Marshal